



ISO 9001 : 2015

Industrial Testing Laboratory & Consulting House

(A Govt. Approved Laboratory)

Analysis Report

NOISE ANALYSIS REPORT

Test Report No. : ITL/ED/01
 Dispatch Date : 16.04.2019

1.	Laboratory Sample No.	ITL/04-19/625/01	
2.	Issued to	M/S INDOGULF CROPSCIENCE PVT. LTD. VPO NATHUPUR, DISTT. SONEPAT Haryana	
3.	Name of sample collecting officer	By Lab Representative	
4.	Type of sample	Noise	
5.	Date & Time of sample collection	09.04.2019	
6.	Date & Time of sample receipt in lab	10.04.2019	
7.	Location of sampling point	Acoustic Room inside and Outside (380 KVA)	
	Date of receipt of Job	11.04.2019	Date of completion of Job
			16.04.2019

OBSERVATIONS

Sr. No	Point of measurement Acoustic Room	I	II	III	IV	V	VI
1.	Inside	98.6	97.9	98.9	96.7	99.1	98.3
2.	Outside (1.0 m away from DG)	70.9	71.6	70.2	72.9	71.8	70.3

TEST RESULTS

Sr. No.	Point of Measurement	Noise Level (dB)			Insertion Loss (dB)*
		Min.	Max.	Average	
1.	Inside	96.7	99.1	98.2	26.9
2.	Outside (1.0 m away from DG)	70.2	72.9	71.3	

Remarks: Analyzed Parameters meet the Standards Limits. *Insertion Loss shall be minimum 25 dB (Standard limit).

Roger
ANALYST



AUTHORIZED SIGNATORY
 Head- IITLCH Laboratory

NOTE: 1. The results are related to the tested items only 2. Total liability of our laboratory is limited to the invoiced amount. 3. Sample will be destroyed after one month from the date of issue of test certificate unless otherwise specified. 4. Report is not to be produced wholly or in part as an evidence in the court of law and should not be used in any advertising media without the permission in writing from laboratory. 6. In case of any reconfirmation of the contents of the test report is required, please contact the authorized signatory of the test report within 15 days of the issue of the test report.
 Format no. IITLCH/QSF/23/05

Page 1 of 1